

2015 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
7-Jan	114	76	<6	<6	5.90	1.29
7-May	53	61	7	14	3.20	0.86
9-Sep	160	163	6	5	1.90	2.56
18-Nov	86	100	6	5	1.00	0.98
Average	103	100	6	8		

- Effluent standards are: (as per DELGNB certificate S-2628)

CBOD₅ and SS - annual average \leq 25mg/l (SS exception >25mg/l, Jul-Oct.) - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.