

## 2016 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD <sub>5</sub>	SS	CBOD <sub>5</sub>	SS	TKN	TP
20-Jan	91	84	6	5	6.30	1.46
27-Apr	77	125	6	5	1.60	0.96
19-Jul	142	124	6	5	1.30	2.86
9-Nov	71	89	6	5	0.90	2.66
Average	95	106	6	5	2.53	1.99

- Effluent standards are: (as per DELGNB certificate S-2628)

**CBOD<sub>5</sub> and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.)** - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD<sub>5</sub>**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.