

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB		Francis LeBlanc	Francis.LeBlanc@gnb.ca	OR	506-856-2374

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
 Release of Untreated wastewater *diluted*
 Unplanned discharge
 Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
 Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: #2 (227 Main St) , #3 (38 Dock St)
 Lift Stations: _____

Start of event: Known Estimated

Date: Saturday January 13, 2018

LS#2 started ≈ 7:30am ≈ 20 us gal/min
 LS#3 started ≈ 8:30am ≈ 10 to 20 us gal/min

Time: _____

Flow: _____ Units: usgpm Known Estimated
 Total volume: _____ Units: _____ Known Estimated
 Fecal coliform: _____ MPN/100mL Known Estimated

Comments: * Caused by heavy rain + snow melt

Reported by (name): Joey Frechette Position: General Manager

Phone: (506) 533-0039 Date: Jan 15, 2018

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@df-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB	Francis LeBlanc	Francis.LeBlanc@gnb.ca	OR	506-856-2374

ATTENTION: This is to notify you the following event has ENDED:

- * Release of Partially-treated wastewater Unplanned discharge
 Release of Untreated wastewater *diluted* Planned discharge

Comments: LS#2 stopped overflowing ≈ 5:00pm Saturday Jan 13 2018
LS#3 stopped overflowing ≈ 3:00pm Saturday Jan 13, 2018

Reported by (name): Joey Frenette Position: General Manager
 Phone: (506) 533-0039 Date: Jan 15, 2018