

2017 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
01-Feb	75	101	6	5	8.50	2.02
27-Apr	58	62	12	17	6.40	2.28
12-Sep	80	75	6	5	1.40	2.66
08-Nov	49	48	6	5	1.90	2.81
Average	66	72	8	8	4.55	2.44

- Effluent standards are: (as per DELGNB certificate S-2628)

CBOD₅ and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.) - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.